

ZIONSVILLE WASTE WATER MONTHLY REPORT

	<u>JUNE 2010</u>	<u>JUNE 2009</u>
TOTAL FLOW	41.6 Million Gallons	32.1 Million Gallons
HIGHEST DAILY FLOW	4.06 Million Gallons	1.582 Million Gallons
AVERAGE DAILY FLOW	1.388 Million Gallons/Day	1.072 Million Gallons/Day
PRECIPITATION	11.4in	4.8 in
NPDES VIOLATIONS	0	0

ADDITIONAL COMMENTS

- A near record rainfall was recorded at the wastewater plant in June with a total of 11.4 inches being measured. The highest flow during the month was on the 22nd of the month where we recorded a total of 4.06 million gallons through the plant. While this is nearly four times our usual dry weather flow we did not exceed any of our NPDES limits. We also experienced high levels in some of our pumping stations but did not overflow in any part of our collection system.
- Contract documents and the Notice To Proceed were signed for the 2010 Sewer Project. The contractor, Insituform Technologies USA, Inc., now has until September 1, 2010 to complete the project.

Respectfully submitted,

Dennis Mackey
W.W. Dept. Superintendent

ZIONSVILLE WASTE WATER MONTHLY REPORT